



0000160000

EAGLETAIL WATER CO
2015
DOCKET CONTROL

Enclosed Find yearly water loss report
for 2014.

DOCKET NO W-03936A-04-0840
DECISION NO 67982

ORIGINAL

Arizona Corporation Commission

DOCKETED

FEB 12 2015

DOCKETED BY	
-------------	---

AZ CORP COMMISSION
DOCKET CONTROL

2015 FEB 12 A 10:29

RECEIVED

EAGLETAIL WATER CO., LLC

P.O. Box 157
Tonopah, AZ 85354
928-372-2236

RECEIVED

2015 FEB 12 A 10: 29

AZ CORP COMMISSION
DOCKET CONTROL

January 29, 2015

Docket Control
Arizona Corporation Commission
1200 West Washington Street
Phoenix, AZ 85007

Re: Docket No. W-03936A-04-0840
Decision No. 67982

Yearly water loss report for 2014.

Enclosed are copies of water loss and water sold for the calendar year 2014. We have repaired (06) major leaks in 2014. We have had several leaks that we had trouble determining the amount of water lost. All of our workers are volunteers. We are down to just several people doing all the work. The youngest is mid 50's the oldest mid 70' We definitely are in need of new ownership.

Our water lines consist of approximately 30 miles of pipe through rural areas and a leak is not always discovered as quickly as we would like. We will continue to monitor our lines as we work towards reaching our goal of 10% or less water loss.

Our total gallons of water pumped for the year is 5,990,400gal and the gallons sold are 3,227,681gal.

If you have any questions regarding this report please call 928-372-2236 or contact us by mail at the address above.

Respectfully,
Eagletail Water Co., LLC

COMPANY NAME: EAGLETAIL WATER CO LLC 2014

WATER USE DATA SHEET BY MONTH FOR CALENDAR YEAR

MONTH	NUMBER OF CUSTOMERS	GALLONS SOLD	GALLON PUMPED (Thousands)
JANUARY	52	184010	378600
FEBRUARY	52	184050	358700
MARCH	52	328620	377100
APRIL	53	220540	1087400
MAY	53	310060	362400
JUNE	53	493940	365300
JULY	55	301040	361100
AUGUST	55	367130	732900
SEPTEMBER	56	210120	340100
OCTOBER	56	242390	382400
NOVEMBER	52	252350	788300
DECEMBER	52	195761	456100
TOTAL		3227681	5990400

Is the Water Utility located in an ADWR Active Management Area (AMA)?

() Yes (X) No

Does the Company have an ADWR Gallons Per Capita Per Day (GPCPD) requirement?

() Yes (X) No

If yes, provide the GPCPD amount: _____

What is the level of arsenic for each well on your system. 0.0005 mg/l
(If more than one well, please list each separately.)

Note: If you are filing for more than one system, please provide separate data sheets for each system.